

## NOTES:

- MADE IN THE U.S.A.
- U.S. PATENT No. 5,863,128
- U.S. No. 3,852,076 AND INTERNATIONAL REGISTERED TRADEMARKS
- 4. MATERIAL: GLASS FILLED POLYPROPYLENE (PP) OR POLYVINYLIDENE FLUORIDE (PVDF) OR NATURAL POLYVINYLIDENE FLUORIDE (N-PVDF)
- 5. INLET/OUTLET CONNECTIONS: 4" DIA, MNPT OR BSPT
- 6. SUCTION PORT CONNECTIONS: 2" MNPT OR BSPT
- 7. FOR INSTALLATION RECOMMENDATIONS REFER TO MAZZEI TECHNICAL BULLETINS No. 4, No. 5, No. 6, No. 10 AND No. 11, WHICH CAN BE FOUND AT WWW.MAZZEI.NET.
- 8. MAZZEI INJECTOR CO., LLC. 500 ROOSTER DR. BAKERSFIELD, CA 93307 TEL: 661.363.6500 WEB: WWW.MAZZEI.NET




	UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES			M	TITLE: 4" INJECTOR; MODEL 4091				
	DRAWN:	J. PEREZ	Wa	V	DRAWING	G NO.:			
	DATE:	9/25/2014							4091
ı			SIZE:	WEIGHT:		SCALE:	REV.:	SHEET:	
	APPROVED:	T. JOHNS	<u> </u>	N/A	١	1:6	С	10	F 2



## NOTES:


- MATERIAL OF CONSTRUCTION: TYPE 316L, STAINLESS STEEL
- MTR/HEAT NUMBERS ARE PROVIDED AND SHALL MEET APPLICABLE MATERIAL SPECIFICATIONS.
- 3. FLANGE BOLT HOLES TO STRADDLE COMMON CENTERLINES, UNLESS OTHERWISE NOTED.
- INLET/OUTLET CONNECTION: 4" DIA., ANSI B16.5, CLASS 150, SCHED. 40, RAISED FACE - WELD NECK FLANGE.
- SUCTION PORT CONNECTION: 3" DIA., ANSI B16.5, CLASS 150, SCHED. 40, RAISED FACE - WELD NECK FLANGE.
- WELDING JOINTS TO BE COMPLETE JOINT PENETRATION, WHERE POSSIBLE.
- DYE PENETRANT TESTING IN ACCORDANCE WITH ASME B31.3 NORMAL SERVICE RECOMMENDATIONS WILL BE PERFORMED ON A MINIMUM OF 20% OF LINEAR LENGTH OF WELDS: OR HYDROSTATIC TESTING WILL BE PERFORMED AS PART OF MAZZEI'S NON-DESTRUCTIVE TESTING PROCEDURE.
- CLEANED FOR PASSIVATION PER ASTM A380 GUIDELINES. 8.
- PASSIVATED PER ASTM A967 SPECIFICATION.
- WELD MAP, NON DESTRUCTIVE TESTING (NDT), CLEANING AND 10. INSPECTION REPORTS TO BE PROVIDED BY MAZZEI.
- MAZZEI RECOMMENDS INSTALLING THE INJECTOR IN A HORIZONTAL POSITION. INJECTORS MAY BE INSTALLED IN A VERTICAL POSITION WITH THE LIQUID FLOW UPWARDS. HOWEVER, IN CERTAIN APPLICATIONS THIS MAY AFFECT PERFORMANCE. PLEASE REFER TO MAZZEI TECHNICAL BULLETIN No. 11; "MAZZEI INJECTOR INSTALLATION RECOMMENDATIONS FOR GAS TO LIQUID MIXING APPLICATIONS".

	REVISIONS							
REV.	DESCRIPTION	DATE	APPROVED					
В	UPDATED NOTE 11.	5/6/2013	P. BANKOWSKI					



## **SUBMITTAL DRAWING**

SUBMITTAL NOTICE	CONFIDENTIALITY NOTICE	UNLESS OTHERWISE SPECIFIED	APPROVALS	DATE	<b>M</b>	MAZZEI INJECTOR CO., LLC
ANY RECOMMENDATIONS FOR PRODUCT AND/OR SYSTEM DESIGN, WHETHER CONTAINED IN A DOCUMENT,	THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF	DIM ARE IN INCHES TOL ON ANGLE ± .1/2°	DRAWN: T. JOHNS	12/28/2012	W9ZZGI,	500 ROOSTER DRIVE BAKERSFIELD, CA 93307 PHONE: (661) 363-6500 FAX: (661)363-7500 WWW.MAZZEI.NET
WITHIN THIS DRAWING, COMMUNICATED BY ELECTRONIC MEANS OR GIVEN VERBALLY, ARE INTENDED SOLELY AS	MAZZEI INJECTOR COMPANY LLC. ANY REPRODUCTION IN PART OR AS A WHOLE	1 PL ± .125 2 PL ± .060 3 PL ± .030 INTERPRET DIM AND TOL PER	CHECKED: P. BANKOWSKI APPROVED:	12/28/2012	TITLE:	
GUIDELINES TO ACTUAL SYSTEM DESIGN. SAID RECOMMENDATIONS ARE BASED UPON INFORMATION	WITHOUT THE WRITTEN PERMISSION OF	ASME Y14.5M-1994	P. BANKOWSKI	12/28/2012	IINJE(	CTOR; MODEL SSF04091AAA00
SUPPLIED BY OTHERS, THE ACCURACY OF WHICH IS	MAZZEI IS STRICTLY PROHIBITED.	THIRD ANGLE PROJECTION	- CUSTOMER APPROVAL:		_	
BEYOND VERIFICATION BY MAZZEI INJECTOR CO. LLC. THEREFOR MAZZEI CANNOT AND DOES NOT WARRANT			CUSTOMER:		SIZE: JOB NO.:	DRAWING NUMBER: REV:
THE SUITABILITY OF ITS PRODUCTS FOR A PARTICULAR SERVICE NOR THE PERFORMANCE OF ANY SYSTEM	Drawing may not be printed full size Do not scale		NA		B NA	
CONTAINING COMPONENTS MADE OR SOLD BY MAZZEI.	DO NOT SCALL				SCALE: NONE	WEIGHT: 72 LBS SHEET: 1 OF 2





MAZZEI INJECTOR CO., LLC 500 ROOSTER DRIVE BAKERSFIELD, CA 93307 PHONE: (661) 363-6500 FAX: (661)363-7500 WWW.MAZZEI.NET

INJECTOR; MODEL SSF04091AAA00

SIZE:	JOB NO.:		DRAWING NUMBER:		REV:
В	NA		SSF04091AAA00-SUB		В
SCALE: 1:5		WEIGHT:	72 LBS SHEET:	2 (	OF 2